

Product Certification Schedule

Schedule No: 046/001/053

Licensee: TRATOS CAVI SPA, 52036 PIEVE S STEFANO (AR), VIA STADIO 2, ITALY

Factory: TRATOS CAVI SPA, 52036 PIEVE S STEFANO (AR), VIA STADIO 2, ITALY

Specification: BS 7870-4.10:2011+ A1:2016 LV and MV polymeric insulated cables for use by distribution and generation utilities - Part 4: Specification for distribution cables with extruded insulation for rated voltages of 11kV to 33kV - Section 4.10 Single-core 11kV to 33kV cables.(Implementation of HD 620)

Type of Cable: Table 2 6.35/11 kV single-core copper wire screened cables
Table 3 12.7/22 kV single-core copper wire screened cables
Table 4 19/33 kV single-core copper wire screened cables

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: Type A: Single-core 70-1000sqmm stranded circular copper or aluminium class 2 conductors, XLPE (DIX 3) or EPR (DIE 5) insulation, bonded extruded semi-conducting insulation screen, copper wire screen, polythene sheath (DMP 5).

Type B: Single-core 70-300sqmm stranded circular copper or aluminium class 2 conductors, EPR (DIE 5) insulation, strippable semi-conducting screen, copper wire screen, low smoke zero halogen sheath (DMZ 4).

Origin Thread: Not applicable

Origin Mark: TRATOS

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 06/07/2017

Signed for and on behalf of the British Approvals Service for Cables

Date 15/11/2016

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

